



## Certificate of Asbestos Analysis

**Prepared for:** 2233 West Main Street  
 Sample City, Wisconsin 53111

**Phone:** (262) 225-9668  
**Email:** hello@wisconsininspection.com

**Test Address:** CLIENT ADDRESS

**Lab COC #:** 52420084

**Date Collected:** 09/01/20XX  
**Analysis Date:** 09/01/20XX

**Receive Date:** 09/01/20XX  
**Report Date:** 09/02/20XX

**Client Sample:** FLOOR1

**Collection Location:** FLOOR1

**Sample Description:** VINYL FLOOR SHEETING

**No Asbestos Containing Material Detected**

**Friable/Homogeneous:** NO/NO

**Layers:** 1

	Layer 1	Intentionally blank	Intentionally blank	Intentionally blank
<b>Description:</b>	VINYL FLOOR SHEETING			
<b>Color:</b>				
<b>Asbestos Type</b>	None Detected			
<b>Other Fibers</b>				
Cellulose	15%	--	--	--
<b>Non-Fibers</b>				
Minerals	85%	--	--	--

**Client Sample:** FLOOR2

**Collection Location:** FLOOR2

**Sample Description:** VINYL FLOOR SHEETING

**Asbestos Containing Material Detected**

**Friable/Homogeneous:** NO/NO

**Layers:** 1

	Layer 1	Intentionally blank	Intentionally blank	Intentionally blank
<b>Description:</b>	VINYL FLOOR SHEETING			
<b>Color:</b>				
<b>Asbestos Type</b>				
Chrysotile	30%	--	--	--
<b>Other Fibers</b>				
Cellulose	20%	--	--	--
<b>Non-Fibers</b>				
Minerals	50%	--	--	--



## Certificate of Asbestos Analysis

---

*Lance R. Cotton*

Analyst

*Lance R. Cotton*

Laboratory Manager

---

This report pertains only to the samples reported and may not be reproduced, except in full, without written permission from PriorityLab. The client is solely responsible for the use and interpretation of this report. This report shall not be used to claim product certification, approval, or endorsement by NVLAP, NIST, or any agency of the US government. Samples analyzed using Code 18/A01: EPA 40 CFR Appendix E to Subpart E of Part 763, Interim Method of the Determination of Asbestos in Bulk Insulation Samples, and Code 18/A03: EPA/600R-93/116 Method for the Determination of Asbestos in Bulk Building Materials. Furthermore, PriorityLab's liability is limited to the cost of the analysis. Limit of Quantitation (LOQ) is 1%. "Trace", if listed, indicates the presence of asbestos below the LOQ. "ND" = None Detected. Floor tile is non-homogeneous and results only reflect sample content.

EPA requirements for reporting and analyzing asbestos are: Asbestos Containing Material (ACM) = equal to or greater than 1%; Non-Asbestos Containing (NAD) is < 1% asbestos, even though the sample may contain a trace amount of Asbestos. If the PLM method is >1% a point count may be performed (but is not required) at the client's request for an additional fee. PriorityLab is not able to assess the degree of hazard resulting from materials analyzed. PriorityLab reserves the right to dispose of all samples after a period of thirty (30) days. Laboratory reports will be kept for a period of three (3) years electronically. All samples were received in acceptable condition unless otherwise noted. Visit [www.epa.gov/iaq/asbestos.html](http://www.epa.gov/iaq/asbestos.html) for more information.

---